

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING NO: 7270-1130:159

Page 1 of 1

CATEGORY: Heat Detector

LISTEE: *Honeywell International Inc., 1500 West Dundee Rd., Arlington Heights. IL 60004-1472
Contact: Bob Hodgson (847) 797-4403 Fax (847) 797-3664

DESIGN: Models T4010A1003 1(135 ° F) & T4010A1011 1(200 ° F). Fixed temperature. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation and UL label.

APPROVAL: Listed as fixed temperature heat detectors for use with separately listed compatible fire alarm control units.

XLF: 7270-0061:001

*Rev. 06-14-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**